




ENERG Y IJA
енергия · ενεργεια IE IA

SkyTek

SM36H4M/SMR09HI
M40A-36HFN1-Q/MSR1U-09HRDN1-QRC4W

SEER

SCOP



kW **10,6**
SEER **5,1**
kWh/annum **654**

kW X **10,6** X
SCOP X **3,4** X
kWh/annum X **4306** X

53 dB

69 dB



ENERGIA · ЕНЕРГИЯ · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI

626/2011

SkyTek

Product fiche

Climalux Center SRL/RO

name or trademark		SkyTek
indoor model		SMR09HI (MSR1U-09HRDN1-QRC4W)
outdoor model		SM36H4M (M40A-36HFN1-Q)
Sound power level at standard rating conditions (indoor/outdoor)	[dB(A)]	53/69
Refrigerant type		R410A
GWP		1700~2000
SEER		5.1
Energy efficiency class in cooling		A
Annual electricity consumption in cooling	[KWh/y]	654
Design load in cooling mode (P _{design})	[KW]	10.6
SCOP (average heating season)		3.4
Energy efficiency class in heating (average season)		A
Annual electricity consumption in heating (average season)	[KWh/y]	4306
Warmer heating season		_____
Colder heating season		_____
Design load in heating mode (P _{design})	[KW]	10.6
Declared capacity at reference design condition (heating average season)	[KW]	8.086
Back up heating capacity at reference design condition (heating average season)	[KW]	2.514

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to [1700~2000]. This means that if 1kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be [1700~2000] times higher than 1kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional

SkyTek products are manufactured by GD Midea Air-Conditioning Equipment Cp Ltd in according to EU norms and brand owner prescriptions. Compliant with EU Regulation 626/2011.