



**ENERG**  
енергия · ενεργεια



**SkyTek**

STC07D1NE/STC07D1NE  
MCD-24HRFN1-QRDO/MOCA30U-24HFN1-QRDO

SEER



**A++**

kW **7,0**  
SEER **6,1**  
kWh/annum **402**

SCOP



**A+**

kW **X** **5,8** **X**  
SCOP **X** **4,0** **X**  
kWh/annum **X** **2030** **X**



**61 dB**



**65 dB**



ENERGIA · ЕНЕРГИЯ · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI

626/2011

SkyTek	Product fiche	Climalux Center SRL/RO
name or trademark		SkyTek
indoor model		STC07D1NE(MCD-24HRFN1-QRDO)
outdoor model		STC07D1NE(MOCA30U-24HFN1-QRDO)
Sound power level at standard rating conditions (indoor/outdoor)	[dB(A)]	61/65
Refrigerant type		R410A
GWP		2088
SEER		6,1
Energy efficiency class in cooling		A++
Annual electricity consumption in cooling	[kWh/y]	402
Design load in cooling mode (P <sub>design</sub> )	[KW]	7.0
SCOP (average heating season)		4.0
Energy efficiency class in heating (average season)		A+
Annual electricity consumption in heating (average season)	[kWh/y]	2030
Warmer heating season		_____
Colder heating season		_____
Design load in heating mode (P <sub>design</sub> )	[KW]	5.8
Declared capacity at reference design condition (heating average season)	[KW]	5.244
Back up heating capacity at reference design condition (heating average season)	[KW]	0.556
<p>Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 2088. This means that if 1kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 2088 times higher than 1kg of CO<sub>2</sub>, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional</p>		
<p>SkyTek products are manufactured by GD Midea Air-Conditioning Equipment Cp Ltd in according to EU norms and brand owner prescriptions. Compliant with EU Regulation 626/2011.</p>		